



CITY OF
PORTLAND, OREGON
BUREAU OF BUILDINGS

1120 S.W. 5th Avenue
Portland, Oregon 97204-1992
Mailing Address: P.O. Box 8120
Portland, Oregon 97207-8120
(503) 823-7300
FAX: (503) 823-6983
TDD: (503) 823-6868

To: Walter Heil
Supervisor Electrical Services
Multnomah County


March 5, 1996

Re: Safety / Code Issues - Justice Center
1021 S.W. 4th

Dear Sirs,

At a recent inspection of the Justice Center at 1103 S.W. 3rd, it was identified that several serious deficiencies exist in the fire alarm system and associated low voltage security systems. These issues could pose a possible liability hazard to the County if prisoners were to become trapped or injured due to one of these systems failing to operate properly.

I recommend immediate action to eliminate all hazardous conditions and code deficiencies to your system. This is the first step to gain code compliance.


Max Runyon
Senior Electrical Inspector